

**GOVERNMENT OF PUDUCHERRY
OFFICE OF THE DEPUTY DIRECTOR (IEC)
(STUDENT HEALTH OFFICE)**

No.DD(IEC)/SHO/2025 - 26 | *PS-79* Pondicherry dt: **6 FEB 2026**

SANITARY CERTIFICATE

The Director of Health Department, Puducherry is hereby grants sanitary certificate to the Institution as detailed below:

1)	Name and address of the school	:	DON BOSCO MATRICULATION HIGHER SECONDARY SCHOOL, Tagore Nagar, Lawspet, Puducherry - 605008
2)	Academic year	:	2025 - 2026
3)	Date of Inspection	:	18 - 08 - 2025
4)	Date of submission of Compliance Report	:	16 - 09 - 2025
5)	Date of issuance of Sanitary Certificate	:	26 - 09 - 2025
6)	Remarks (if any)		Issued after request from the School vide letter dated 24 - 02 - 2026

2. The management of the said school is informed that all the conditions as stipulated in the remarks and those prescribed in the Pondicherry School Education Rules, 1996 should be fulfilled failing which further continuance of renewal of sanitary certificate is liable to be rejected by this competent authority.



K. Vivekananda
6/3/2026

**STUDENT HEALTH OFFICER
O/o DD [I.E.C.], DHFWS**

**Dr. K. VIVEKANANDA,
STUDENT HEALTH OFFICER
O/o Deputy Director (IEC)
DEPARTMENT OF HEALTH & FAMILY WELFARE SERVICES.
PUDUCHERRY.**

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY



Report No. : TR/WTL/PHD/PWD/PDY/2024/W-1939
ULR-TC758024000001074F

Date: 25.09.2024

TEST REPORT- CHEMICAL

Customer Name & Address : Don Bosco Matriculation Higher Secondary School,
Tagore Nagar, Puducherry-605008.

Customer Reference : Letter No. Nil, dt:23.09.2024

Page 1 of 1


SAMPLE DETAILS

Sample Code	: 2024/W-1939	Information provided by the Customer	
Product Category	: Water	Sampled on	: 23.09.2024
Sample Name	: Drinking Water	Sample Description	: Tap Water
Sample Condition	: Fit for analysis	Sample Source	: -
Sampled by	: Customer	Identification by Customer	: Sample - D
Sample Received on	: 23.09.2024	Sampling Location	School Campus, Tagore Nagar, Puducherry.
Test Started on	: 23.09.2024		
Test Completed on	: 25.09.2024		

TEST RESULTS

CHEMICAL REPORT					
Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 23rd Edition, 2017, 4500-H ⁺ B	--	6.52	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 23rd Edition, 2017, 2510 B	µs/cm	172	---	---
Table 2 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Alkalinity as CaCO ₃	APHA, 23rd Edition, 2017, 2320 B	mg/L	26.0	200 Max	600 Max
Total Hardness as CaCO ₃	APHA, 23rd Edition, 2017, 2340 C	mg/L	54.7	200 Max	600 Max
Calcium as Ca	APHA, 23rd Edition, 2017, 3500-Ca B	mg/L	13.5	75 Max	200 Max
Magnesium as Mg	APHA, 23rd Edition, 2017, 3500-Mg B	mg/L	5.13	30 Max	100 Max
Iron as Fe	APHA, 23rd Edition, 2017, 3500 Fe B	mg/L	<0.10	1.0 Max	No Relaxation
Chloride as Cl	APHA, 23rd Edition, 2017, 4500-Cl B	mg/L	30.9	250 Max	1000 Max
Sulphate as SO ₄	APHA, 23rd Edition, 2017, 4500-SO ₄ E	mg/L	<5.00	200 Max	400 Max
Fluoride as F	APHA, 23rd Edition, 2017, 4500-F D	mg/L	<0.10	1.0 Max	1.5 Max

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PUDUCHERRY

Copy submitted to:
The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHD/PWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No. : TR/WTL/PHD/PWD/PDY/2024/W-1939(Annexe)

Date:25.09.2024

TEST REPORT- CHEMICAL

Customer Name & Address : Don Bosco Matriculation Higher Secondary School,
Tagore Nagar, Puducherry-605008.

Customer Reference : Letter No. Nil, dt.23.09.2024

Page 1 of 1

SAMPLE DETAILS

Sample Code	: 2024/W-1939	Information provided by the Customer	
Product Category	: Water	Sampled on	: 23.09.2024
Sample Name	: Drinking Water	Sample Description	: Tap Water
Sample Condition	: Fit for analysis	Sample Source	: -
Sampled by	: Customer	Identification by Customer	: Sample - D
Sample Received on	: 23.09.2024	Sampling Location	School Campus, Tagore Nagar, Puducherry.
Test Started on	: 23.09.2024		
Test Completed on	: 25.09.2024		

CHEMICAL REPORT

CHEMICAL REPORT					
Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/ dt.23.9.18	mg/L	107	500 Max	2000 Max

.....End of Report.....


Authorized Signatory

L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PUDUCHERRY.

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No: TR/WTL/PHD/PDY/2024/B-0368

Date: 25.09.2024

TEST REPORT

Page 1 of 1

Customer Name & Address : Don Bosco Matriculation Higher Secondary School,
Tagore Nagar, Puducherry-605008.
Customer Reference : Letter No Nil, dt.23.09.2024

SAMPLE DETAILS

SAMPLE DETAILS				
Sample Code	2024/B-0368	Sampled by	Customer	
Sample Name	Water	Sampled on	23.09.2024	
Sample Description	Treated Water	Sampling Location	School Campus, Tagore Nagar, Puducherry.	
Temperature	--	Sampling Procedure	--	
Identificaion by Customer	Sample - D	Sample Received on	23.09.2024	
Sample Condition	Fit for analysis	Test Completed on	25.09.2024	
Test Started on	23.09.2024			
Test Parameter	Test Method	Units	Results	Drinking water standard requirements as per IS 10500-2012
BACTERIOLOGICAL ANALYSIS				
Total Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent
Faecal Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent

Remarks:

The water sample meets the requirement of the standards in respect of the above parameters analysed.

L. Anita Ben
Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PUDUCHERRY.

Copy to:

The Executive Engineer,
P.H.D., P.W.D., Puducherry.

Terms and Conditions

- The test result relevant only to the item tested
- The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
- The laboratory is not responsible for the authenticity of photocopied test report
- The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations
- The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.